



D.B. Wilson Station
5663 State Route 85 West
Centertown, KY 42328
www.bigrivers.com

December 6, 2018

Re: Big Rivers Electric Corporation D.B. Wilson Station (AI 3319) Notification of Statistical Exceedance above the Groundwater Protection Standard and Notification of Intent to Initiate an Assessment of Corrective Measures

Big Rivers Electric Corporation's D.B. Wilson Station CCR Landfill notification of one constituent in appendix IV, collected and analyzed under assessment monitoring 40 CFR Part 257.95, has been detected at statistically significant levels above the groundwater protection standard. Cobalt at monitoring well MW-10 showed an exceedance of the groundwater protection standards.

The Coal Combustion Residuals Rule 40 CFR Part 257.95(g) requires that a facility place formal documentation in their operating log within thirty days that one or more constituents in appendix IV to this part has been detected at statistically significant levels above the groundwater protection standard per 40 CFR Part 257.105(h)(8).

Big Rivers Electric Corporation D.B. Wilson Station is supplying this document as formal notification that the D.B. Wilson Station CCR Landfill will initiate an assessment of corrective measures per 40 CFR Part 257.95(g)(1-5). The document fulfills the requirement of 40 CFR Part 257.105(h)(9).